

Addendum #1



To: Prospective Bidders

File No: RFP 2023-06 RTQ #1

Date: November 21, 2023

From: Brian Murphy, Director of Public Works & Engineering

Re: Response to Bidder Questions #1 RFP 2023-06

Please review the following responses to bidder questions that have been submitted in regards to City of Duncan RFP 2023-06 Gibbins Reservoir – Tank #2 Reservoir Lining Engineering Services

1. What are the reservoir tank's dimensions?

Round, 22m inside diameter, 9.202m inside height.

2. Are as-built drawings available?

There is a package of as-built drawings available. These would need to be sent or received through file transfer due to large size. Please contact engineering@duncan.ca to request the files.